




Apartment Block



Region	north
Age Class	1995-2001
Net leased area [m ²]	1450.8
Storey Height [m]	2.7
Storeys a.g.	3.0



Exterior Wall

Type: lightweight-wooden	U [W/m ² K]		
	Actual: 0.270	Min: 0.140	Max: 0.400

Layer	Material Name	t _i [m]	ρ _i [kg/m ³]	λ _i [W/mK]	c _i [J/kgK]	EPD ₁	EPD ₂
0	plaster board	0.013	732	0.21	1384	13	-
1	wooden stand	0.2	650	0.21	1500	12	-
2	mineral wool	0.1	60	0.04	850	2	-
3	cement	0.02	1800	0.35	850	10	-

Interior Wall

	U [W/m ² K]		
	Actual: 0.650	Min: 0.140	Max: 0.300

Layer	Material Name	t _i [m]	ρ _i [kg/m ³]	λ _i [W/mK]	c _i [J/kgK]	EPD ₁	EPD ₂
0	lime plaster	0.1	1600	0.7	850	13	-
1	hardwood	0.15	650	0.14	1500	12	-
2	lime plaster	0.1	1600	0.7	850	2	-


Roof

Type: wooden	U [W/m ² K]		
	Actual: 0.150	Min: 0.140	Max: 0.400

Layer	Material Name	t _i [m]	ρ _i [kg/m ³]	λ _i [W/mK]	c _i [J/kgK]	EPD ₁	EPD ₂
0	gypsum plasterboard	0.013	900	0.21	1228	15	-
1	rafters	0.08	600	0.13	1500	14	-
2	moving air layer	0.06	1.184	0.0261	1.005	7	-
3	polystyrene	0.12	40	0.035	1380	1	-
4	roof tiles	0.02	1786	0.55	889	8	-



Apartment Block



Region	north
Age Class	1995-2001
Net leased area [m²]	1450.8
Storey Height [m]	2.7
Storeys a.g.	3.0



Foundation

Type: massive	U [W/m²K]		
	Actual: 0.570	Min: 0.160	Max: 0.600

Layer	Material Name	t _i [m]	ρ _i [kg/m³]	λ _i [W/mK]	c _i [J/kgK]	EPD ₁	EPD ₂
0	floating cement screed	0.04	2000	1.4	1000	16	-
1	polystyrene	0.05	40	0.035	1380	1	-
2	reinforced concrete	0.16	2400	2.1	776	6	-

Floor

U [W/m²K]		
Actual: 0.650	Min: 0.140	Max: 0.300

Layer	Material Name	t _i [m]	ρ _i [kg/m³]	λ _i [W/mK]	c _i [J/kgK]	EPD ₁	EPD ₂
0	cement screed	0.04	1950	1.4	1000	5	-
1	mineral wool	0.04	60	0.04	850	2	-
2	reinforced concrete	0.2	2400	2.1	776	6	-

Window System


Glazing	EPD _{Gl}	Frame type	EPD _{Fr}	window wall share
2	11	pvc	3	0.19497

Heating System

Generator 1	EPD	Heating energy carrier	EPD
boiler_gas_medium_condensing	9	gas	4



Apartment Block




Region	north
Age Class	1995-2001
Net leased area [m²]	1450.8
Storey Height [m]	2.7
Storeys a.g.	3.0



EPD Summary Table

SPN	Full EPD ID	Material Title
1	4e83c488-bb36-40b0-bfd4-b2aa7f1c0f04	Expanded Polystyrene (EPS) Foam Insulation (density 30 kg/m³)
2	50d421e2-3a7b-4659-92a4-f20d6a52fcf0	Mineral wool (facade insulation)
3	73de9e80-8ed2-47d8-b5b6-854c84166f24	Window sash PVC-U
4	84aa7483-9824-49a9-a3e3-f9fb092ea7b7	Use - 1 kWh of final energy from gas calorific value (according to GEG)
5	86d919ee-8f30-4ca4-9b7e-717aecba6ac0	Cement screed
6	Synthetic_2	Concrete C30/37 with reinforcement steel
7	Synthetic_8	Air layer
8	a6d60a75-7a4e-4dfc-87cc-fd40f68d279a	Roofing tiles (including accessories)
9	ce333ecb-6cad-441c-9dae-70966acf9333	Gas condensing boiler 20-120 kW (upright unit)
10	d368f4bb-ae22-4e33-b9e4-22a7b27966c6	average cement D
11	dcf38066-e336-46a7-b0a8-b2453dd2872d	Window glass, single
12	e70d9027-5315-481c-92e2-7b7d8a02eaba	holzius ? solid wood slab elements
13	edec09e1-c56e-4655-a094-c9a18e1563ac	Gypsum plaster board (perforated, 12.5 mm)
14	efa55966-4f29-4f15-bfec-8c08b3945923	Glued laminated timber
15	f6878cee-a4bd-43da-a830-c64b975cb957	DRY SCREED PLASTERBOARD / Tool
16	fe371be5-c72f-4203-8569-a085ef375ba4	CALCIUM SULPHATE FLOWING SCREED AND CONVENTIONAL CALCIUM SULPHATE SCREED



This archetype represents :

- **0.07%** of all Apartment Blocks
- **0.14%** of all Apartment Blocks of the specific region

Data source	Link
Altbauatlas	https://www.altbauatlas.de/index.php
OEKOBAUDAT	https://www.oekobaudat.de/en.html
IWU	https://datenbasis.iwu.de/ https://wohngebaeuedaten2016.iwu.de/
MASEA	https://www.masea-ensan.de/
TEASER	https://ebc-tools.eonerc.rwth-aachen.de/en/teaser
EU BSO	https://building-stock-observatory.energy.ec.europa.eu/database/